

PRIMARY HEALTH CENTRE ,EZHUKONE

Ezhukone(P.O) Kollam(Dt) 0474 2484737 , E-Mail : phcezhukone@yahoo.com

CERTIFICATE

Certified that the sanitary facilities of **Sree Narayana Guru Central School, Ezhukone Kottarakara** owned by Sree Narayana Guru Trust, Ezhukone Reg. No: **2655/2001** has been inspected and found the following Public Health Conditions.

- | | |
|-----------------------|-----------------|
| 1) Water Supply | : Sufficient |
| 2) Hygenic Conditions | : Good |
| 3) Ventilation | : Sufficient |
| 4) Others | : Satisfactory. |

The validity period of this certificate is only one year.

This certificate is issued to produce before the CBSE Authorities.

Ezhukone

29/07/2022



Health Inspector

PHC Ezhukone

Kollam

For Libin

Health Inspector
PHC, Ezhukone
Pavithreshwaram



काश्यू भवन, मुन्दक्कल, कोल्लम- 691001, केरल, भारत. CIN:U74999KL1955NPL000300

Cashew Bhavan, Mundakkal, Kollam - 691 001, Kerala, India. Tel: +91 474 2761003, 2742704

Fax: +91 474 2742704, Email: cepcilab@cashewindia.org, Web: www.cepcilab.org

TEST CERTIFICATE
ORIGINAL

Date : 21 Jul 2022

ULR - TC608822000033025F

No : 3438

CUSTOMER ADDRESS	SAMPLE DETAILS
Name & Address : Sree Narayanaguru Central School Ezhukone, Kottarakkara	Reg.No : CEPC/1941/22-23 Customer Reference : Letter Dated 14/07/2022 Sampling details : H.I. P.H.C Ezhukone Pavithreshwaram Identification Code :
Other details if any : Sample No:10/2022, Date & Time of sample Collection:14/07/2022, 1.15 PM	Type of Sample : Well Water Sample Description : Colourless liquid with tiny suspended particles Condition of the sample : Satisfactory Date of Receipt : 14 Jul 2022 Date of Starting : 14 Jul 2022 Date of Completion : 21 Jul 2022 Condition of packing : Unsealed Plastic can

Table 1. Organoleptic and physical Parameters

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Colour , Hazan Unit	Lessthan1	IS 3025 (part 4):2002	5
II	Odour	Agreeable	IS 3025 (part 5):2002	Agreeable
III	pH	6.8	IS 3025 (part 11):2002	6.5 -8.5

Page 1 of 2

Authorized Signatory
(Chemical)

AJINI. A.S
Scientist



Authorized Signatory
(Microbiology)

MAYARANI. C.B
Assistant Principal Scientist

● This Test Certificate refers only to the item tested.

● This certificate, if reproduced, shall only be in full.

● Written approval of the Lab-in-charge is necessary for reproduction of this certificate.



ORIGINAL

Date : 21 Jul 2022

ULR - TC608822000033025F

No : 3438

IV	Turbidity ,NTU	Not Detected(Det:Limit0.2)	IS 3025 (part 10):2002	1
V	Total dissolved solids ,mg/l	140	IS 3025 (part 16):2002	500

Table 2. General Parameters Concerning Substances Undesirable in Excessive Amounts

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Fluoride (as F) ,mg/l	Not Detected(Det:Limit0.1)	IS 3025 (part 60):2008	1
II	Chloride (as Cl) ,mg/l	22.7	IS 3025-1992 (part 32)	250
III	Total Hardness (as CaCO ₃) ,mg/l	42.8	IS 3025 (Part21):1996	200

Microbiological Analysis

Sl.No	Parameters	Results	Test Methods	Acceptable Limit (IS 10500 : 2012)
I	Total Coliforms ,in 100ml	Absent	SOP-MOAB/AP/DW-9 Issue No: 1 dated 03.12.2018	Absent in 100ml
II	E.coli or Thermotolerant coliform bacteria ,Presence/Absence in 100 ml	Absent	SOP-MOAB/AP/DW-10 Issue No: 1 dated 03.12.2018	Absent in 100ml

Note : The test report is as per the details and samples provided to this laboratory in Kollam.

-- End of Report --

Page 2 of 2

Authorized Signatory
(Chemical)

AJINI. A.S
Scientist



Authorized Signatory
(Microbiology)

MAYAKANI. C.B
Assistant Principal Scientist.